



## Solicitation Solicitation Amendment

1. Amendment Number <b>A01</b> to Solicitation Number <b>162640-08-A-0084</b>		Date <b>03/11/2008</b>	
2a. Facility <b>Aurora IL - FOX VALLEY P&amp;DC</b>	2b. Project <b>J84862</b> <b>Roof Replacement</b>		
3a. Offeror Name and Address	3b. Issued By <b>GREAT LAKES FSO</b> <b>62 STRATFORD DR</b> <b>BLOOMINGDALE, IL 60117-7000</b>		
	3c. Contact <b>VINOD N MODY</b> <b>630-295-6212</b>		
4. The above numbered solicitation is amended as set forth in Block 5. Note: Offerors must acknowledge receipt of this amendment prior to the date and time specified in the solicitation by one of the following methods: a. By signing and returning one copy of the amendment; b. By acknowledging receipt of this amendment on each copy of the offer submitted; or c. By submitting a separate letter or telegram which includes a reference to the solicitation and amendment numbers.  FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE SPECIFIED IN THE SOLICITATION PRIOR TO THE DATE AND TIME SPECIFIED FOR RECEIPT OF OFFERS MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment, you desire to change an offer already submitted, such change may be made by telegram or letter provided such telegram or letter makes reference to the solicitation and amendment numbers, and is received prior to the date and time specified. The date and time specified for receipt of offers is:  <b>03/20/2008 03:00 PM</b>			
5. Description of Amendment:  Attached:  Management Plan submittal date has been extended to Thursday, March 13, 2008 by 3:00 p.m. CST. Proposal due date unchanged.  (1 pg) Summary of Drawing Revisions (1 pg) Revised Schedule of Values			
6. Contractor Signature <i>[Signature]</i>	Date Signed	U. S. Postal Service Signature <i>[Signature]</i>	Date Signed <b>3/11/08</b>
Name of person authorized to sign <i>[Signature]</i>		Contracting Officer <b>EDWIN BRODERICK</b>	

AMENDMENT NO. 1

03-10-2008

FOX VALLEY P+DC, AURORA, IL 60599  
Replace Roofing System

Solicitation No.: 162640-08-A-0084  
USPS FMS NO. J84862

TENG & ASSOCIATES, INC. - PROJECT NO. 20001.054

IEM 1 - DRAWING REVISIONS

- A. Drawings A1.02 through A1.04, General Note 9: Revise to read: "Cover entire roof with minimum R-20 polyisocyanurate insulation mechanically attached to metal deck and minimum ½" thick manufacturer-approved substrate board prior to installing single-ply membrane. Attachment of substrate board shall result in a roofing system in compliance with specified Factory Mutual ratings."
- B. Drawings A1.02 through A1.04, New General Note 10: "R-20 is the minimum, not average, insulation value at all areas, including tapered insulation areas."
- C. Drawings A1.02 through A1.04, New General Note 11: "Contractor shall remove and replace satellite dishes. USPS to recalibrate satellite dishes."
- D. Drawings A1.02 through A1.04, New General Note 12: "Standing seam metal roofing at the southern entry shall be installed over a new fully-adhered TPO membrane; clips shall be fastened with TPO-compatible casketed fasteners. See Detail 5, A5.02."
- E. Drawings A1.02 through A1.04, New General Note 13: "Prepare and re-prime 80,000 square feet of the topside of the metal roof decking." Price to be added in Schedule of Values.
- F. Drawings A1.02 through A1.04, New General Note 14: "Contractor shall provide suspended dust/debris protection under areas of work. Approximately 60,000 square feet of the building has ceiling (no protection required) and approximately 343,000 square feet has exposed roof deck (protection required). Fire protection system shall remain fully operational when suspended protection system is in place. Upon proper coordination with and phasing schedule approval by USPS, USPS operations may be suspended under the phased areas of work throughout the project."
- G. Drawing A5.02, Detail 4: Installation of new sheet metal counter-flashing under existing metal cap shall apply to smoke vent curbs.

END OF AMENDMENT NO. 1

