




Solicitation Solicitation Amendment

| | | | |
|--|---|--|----------------|
| 1. Amendment Number A02 to Solicitation Number 162640-07-A-0140 | | Date 08/22/2007 | |
| 2a. Facility INDIANAPOLIS, IN 46206-9997 - P & DC | 2b. Project J42129 Roof Replacement | | |
| 3a. Offeror Name and Address | 3b. Issued By GREAT LAKES FSO 62 STRATFORD DR | | |
| | 3c. Contact EDWIN BRODERICK 630-295-6249 | | |
| 4. The above numbered solicitation is amended as set forth in Block 5. Note: Offerors must acknowledge receipt of this amendment prior to the date and time specified in the solicitation by one of the following methods: a. By signing and returning one copy of the amendment; b. By acknowledging receipt of this amendment on each copy of the offer submitted; or c. By submitting a separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE SPECIFIED IN THE SOLICITATION PRIOR TO THE DATE AND TIME SPECIFIED FOR RECEIPT OF OFFERS MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment, you desire to change an offer already submitted, such change may be made by telegram or letter provided such telegram or letter makes reference to the solicitation and amendment numbers, and is received prior to the date and time specified. The date and time specified for receipt of offers is: 08/27/2007 03:00 PM CST | | | |
| 5. Description of Amendment: This Addendum 2 is issued as a supplement to the plans and specifications and shall be considered an integral part of the same. AD2.1 Specifications 06100: Revise section 06100, 2.5 - A-7 to read: Fasteners for preservative treated lumber must be type 304 or 316 stainless steel. AD2.2 Specifications 07550: Clarification - Both hot applied low emission and cold applied systems are indicated. It is the contractors choice on which system will be most cost effective and time effective to use. AD2.3 Specifications 07550: Clarification - Section 2.8 - The roof system will be required to have a high reflectance (light colored) Energy Star approved coating on the cap sheet. AD2.4 Drawings Sheet A6.01: A vapor barrier will not be required as indicated on the detail. | | | |
| 6. Contractor Signature | Date Signed | U. S. Postal Service Signature | Date Signed |
| | |  | 8/22/07 |
| Name of person authorized to sign | | Contracting Officer JOHN A VLCEK | |



**Facilities Department
Attachment to Amendment**

1. Amendment Number A02 to Solicitation Number 162640-07-A-0140

01 Addendum AD-2



MSKTD

& Associates, Inc.

ARCHITECTURE ENGINEERING INTERIOR DESIGN

930 NORTH MERIDIAN, INDIANAPOLIS, INDIANA 46204 PH. 317-917-1190 FAX 317-822-6236

ADDENDUM AD-2

USPS – INDIANAPOLIS P&DC
MSKTD PROJECT: 4815
AUGUST 21, 2007

This addendum is issued as a supplement to the plans and specifications and shall be considered an integral part of the same.

| ITEM | LOCATION | DESCRIPTION |
|-------|----------------------|---|
| AD2.1 | Specifications 06100 | Revise section 06100, 2.5 – A – 7 to read: Fasteners for preservative treated lumber must be type 304 or 316 stainless steel. |
| AD2.2 | Specifications 07550 | Clarification – Both hot applied low emission and cold applied systems are indicated. It is the contractors choice on which system will be most cost effective and time effective to use. |
| AD2.3 | Specifications 07550 | Clarification – Section 2.8 – The roof system will be required to have a high reflectance (light colored) Energy Star approved coating on the cap sheet. |
| AD2.4 | Drawings Sheet A6.01 | A vapor barrier will not be required as indicated on the details. |

Respectfully submitted,

MSKTD & Associates, Inc.

Robert J. Harmeyer

cc: All Planholders
File